



HELUKABEL®

Certificate of compliance with the order 2.1 according to EN 10 204

HELUKABEL® GmbH

Dieselstraße 8 - 12
71282 Hemmingen/Stuttgart
Germany
Phone (0 71 50) 92 09-0
Telefax (0 71 50) 8 17 86
www.helukabel.de

Date: 01.09.2008
limited in time: 30.06.2009

NSGAFÖU 3KV

We confirm that the above mentioned special rubber insulated single core cable are produced according to DIN VDE 0250 part 602 and tested according to DIN VDE 0472/0473.

- **Temperature range**
 - flexing - 25 °C to +80 °C
 - fixed installation - 40 °C to +80 °C
 - Permissible **operating temperature** at conductor +90 °C
- **Nominal voltage:** U₀/U 1,8/3 kV
- **Behaviour in fire** test according to VDE 0482-332-1-2/ DIN EN 60332-1-2/ IEC 60332-1 (equivalent DIN VDE 0472 part 804 test method B).

HELUKABEL® GmbH

i. V. Horst Kappler
Technical Manager

i. A. Rolf Stober
Technical Support

Verkaufsbüro & Lager Berlin
Zum Mühlenfließ 1 · D-15366 Neuenhagen
Tel. 0 33 42/ 23 97-0 · Fax 0 33 42/ 80033

Verkaufsbüro & Lager Chemnitz
Eichelbergstr. 7 · D-09246 Limbach-Oberfrohna
Tel. 0 37 22/ 60 86-0 · Fax 0 37 22/ 60 86-20

Verkaufsbüro Nord
Memeler Weg 12 · 25566 Rethwisch/HH
Tel. 0 48 28/901-082 · Fax 0 48 28/ 901-206

Verkaufsbüro Rhein-Ruhr
Am Handwerkslof 2-4 · D-47269 Duisburg
Tel. 0203/ 73 995-0 · Fax 02 03/ 73 995-10

weitere Niederlassungen: Niederlande · Schweiz · Türkei · Schweden · Frankreich · Tschechische Republik · Polen · Slowakei · China · Süd Korea · Singapur · Indien · Thailand

Geschäftsführer Helmut Luksch · Sitz der Gesellschaft Hemmingen · Amtsgericht Stuttgart HRB 201352 · Ust.-Ident-Nr. DE 146021824
Volksbank Ludwigsburg (BLZ 604 901 50) 45 003 009 · S.W.I.F.T.GENO · IBAN-Nr. DE 39 6049 0150 0045 0030 09
BW Bank, Ludwigsburg (BLZ 604 300 60) 8 326 232 900 · S.W.I.F.T.BWBK DE 6 S HOF · IBAN-Nr. DE 59 6043 0060 8326 2329 00
Commerzbank AG, Böblingen (BLZ 600 400 71) 8 307 522 · Deutsche Bank Leonberg (BLZ 600700 70) 987 616 000 · Kreissparkasse Böblingen (BLZ 603 501 30) 8 675 073